

This brief is being provided to inform the board, staff, and public of the details of an agenda item that requires no action from the board. The President of the Board will provide board members, staff, and the public the opportunity to ask questions about this topic when this agenda item is announced.

Date: 11/13/2023

Originator: General Manager

Agenda Topic Title: General Manager Report

Purpose of Brief: Informational Briefing

Supporting Documents Included: Yes

Water Distribution System:

- Well 29 Grant Project Tank Pad and Road are completed as well as all trenches. Foundation excavation and foundation rebar has been completed and the Tank is on site.
- Booster Stations – All working well.
- New WB DDW Draught Report required for the GM CSD system. (Safer Clearinghouse Report)
- Total Water production Sep 1,327,638 Gal.

Sewer Transmission System and Septic Tanks:

- Leach Fields - Falling Water Leach field expansion completed and working perfect.
- Falling Water Leach Field CV Salts average is about 650 PPM for this month (Maxum Contaminant level) is 700 PPM.
- The Septic tank inspections – Completed for 2023 18 tanks pumped.
- 3 Qtr. State report Done.
- Total Sewer Flows 357,837 Gal.

Financial Reports

- P&L
- Aging report

Other Discussion

- Fall Newsletter
- Staff and Board Trainings
- Zero-Emission Vehicle regulation 2035
- 5-year Master plan update

- Customer Burn Pile Charge