



Indian Valley Community Services District

Providing services for our community health, well-being, and prosperity

Utility Manager Operations Report

Began preparation for the construction of 19 new homes throughout Greenville by visiting each lot and identifying available utilities at each parcel. Ordered 20 new ¾” meters for these lots which will accommodate the duplexes that are going to be built.

Identified utilities for the construction of the new Greenville Rancheria Medical Center on 410 Main Street. Advised the contractor that the installation and cost for the new 3” inch water main and 6” sewer will be their responsibility as the existing utilities on the premises were insufficient for the new building codes.

Began performing daily inspections of Bidwell Dam as required in the Emergency Action Plan and documenting our rounds in an official logbook.

Contacted The Wire Wizard to schedule the installation of the surge suppressors at the lift-stations

Conducted maintenance and housekeeping at the Greenville park in preparation for the little league season, met with the landscape contractor for training on the new sprinkler system. Ordered fertilizer and will apply prior to the first irrigation.

Monthly samples for potable water in Greenville and Crescent Mills were taken with negative coliform results prior to chlorination. Quarterly ground water monitoring samples are to be collected for the Greenville and Taylorsville wastewater sites.

Received a quote for the inspection and repair of over 6500 feet of sewer mains around the “Flats” and the total cost was over seven hundred thousand dollars. This would be a good candidate for a grant project to fix the Inflow and Infiltration of ground water into the sewer system. The existing sewer system is from the late 50’s and needs repair.

The Emergency Action Plan for Bidwell Dam is nearly complete, and a tabletop exercise is scheduled for March 20th. Multiple agencies are attending; this presents the opportunity to refresh relationships that will be involved in responding to emergencies relating to the dam. A district meeting amongst all parties involved is required every five years.

